

Approval Number 2209565
Test Report: MA7594/C/1



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

13th March 2024

Plas-Fit Ltd
Unit 18, Whieldon Road
Ind. Est.
Stoke On Trent
ST4 4JP

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYPROPYLENE- COMPONENTS.

5260

'Plas-fit PN 16 Compression Fittings Series 250/ 350'. Black coloured, injection moulded polypropylene fittings. For use with water up to 23°C.

APPROVAL NUMBER: 2209565

APPROVAL HOLDER: PLAS-FIT LTD.

The Scheme reserves the right to review approval.
Approval 2209565 is valid between September 2022 and September 2027

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a horizontal line extending to the right.

Ian Hughes
WRAS Approvals Manager